

Protection of elbows in municipality potable water plant

ID: 9336

Industry: Water / Wastewater **Customer Location:** Ontario, Canada
Application: VPF-Valves, Pipes and Fittings **Application Date:** May 2023
Substrate: Carbon steel
Products: Belzona 1111 (Super Metal), Belzona 1341N (Supermetalgilde)

Problem

Pipe elbows had a concrete liner which was very deteriorated and at times concrete chunks became loose in the system which was unacceptable.

Elbow with deteriorating concrete liner.

Rebuilding deep pitting with Belzona 1111.

Application of stripe coats of Belzona 1341N.

Elbow after application of second coat of Belzona 1341N.

Application Situation

The city had already planned a shutdown to address other equipment in the plant, so they decided to remove the concrete liner in the elbows and change it with a coating that was approved for potable water. The project was divided into 2 phases for a total of 6 elbows.

Application Method

All the elbows were grit blasted to SSPC SP10. They had pitting and irregular welds which were smoothed and filled with Belzona 1111. Then Belzona 1111 was frost blasted, stripe coated and two coats of Belzona 1341N were applied.

Approval Required: NSF

Belzona Facts

We worked closely with the specifier and provided great support. He was very pleased and had no hesitation to recommend Belzona as he knew not only about the quality and proven success of our products, but also the technical support on and off the site. Use of the products in confined space was also lauded compared to competitor's product used on external of the pipe on same project.

For more examples of Belzona Know - How In Action, please visit <https://khia.belzona.com>

ISO 9001:2015
FS 695214
ISO 14001:2015
EMS 695213

Belzona products are
manufactured under an ISO
9000 Registered Quality
Management System.

www.belzona.com


BELZONA[®]
 Repair • Protect • Improve